



PAT McCRORY  
Governor

NICHOLAS J. TENNYSON  
Secretary

December 13, 2016

**NOTICE TO BIDDERS**

Contract No.: DA00330, DA00331 & DA00332

To Whom It May Concern:

Reference is made to the proposal and plans previously furnished for these projects.

A question has been asked regarding the dewatering process, and the need to maintain base flow in the streams by use of a bypass pipe, pump, etc.

**There are no permit provisions that require the installation of a bypass pipe, bypass pump, etc. The transfer of water around the site is the responsibility of the contractor. It would be expected that there would be a need to pump clean water around the site in order to prevent an unsafe rise in water elevation on the upstream side of the site. This work should be incidental to other bid items.**

Sincerely,

DocuSigned by:

A handwritten signature in black ink that reads 'W. B. Hobbs'.

99A5A272ED6A447...

W. B. Hobbs, PE  
Division Project Manager

WBH/ces  
Attachment

cc: A. W. Roper, PE  
C. S. Mebane, PE  
J. S. Abel, Jr.

